



पावर फाइनेंस कॉर्पोरेशन लिमिटेड  
**POWER FINANCE CORPORATION LTD.**  
(भारत सरकार का उपक्रम) (A Govt. of India Undertaking)

No. 02:10:R-APDRP: HP: TPIEA-EA

November 25, 2011

**Shri Akash Jain**  
Managing Director  
Pranat Engineers Pvt. Ltd.  
28, Rishabh Vihar, Karkardooma,  
**Delhi-110092.**

**Sub:** Observations on draft TPIEA-EA reports of 5 towns of Himachal Pradesh (Solan, Yol, Hamirpur, Nahan and Chamba town).

**Dear Sir,**

This has reference to the draft TPIEA-EA reports of 5 towns of Himachal Pradesh (Solan, Yol, Hamirpur, Nahan and Chamba town) submitted vide your letter no. nil dated 04/11/2011. In this regard, our observations on the draft TPIEA-EA reports of above 5 towns are as under:-

**Common for all 5 towns**

1. Meters shown in indicative line along (i.e. towns metering map) page are not matching with corresponding data collection tables.
2. Dates not given on certificates.
3. Procedure for calculations of Arrears to be given in the reports.
4. AT&C losses to be provided up to two decimals.
5. It is advisable to give figures of Energy & amount in KWH and Rs. respectively for minimizing rounding of errors.
6. Physical verification of consumers for any category of the consumers should not be 0.
7. Reasons for arrears in each billing cycle to be given.

**Solan Town**

1. There are 7 boundary points & meters, however in the data collection template only 6 meters data has been shown?
2. In Executive Summary Units of Energy & Amount seems to be incorrect.

**YoL Town**

1. In Data collection template table 3, format has been changed/ not as per standard template.
2. Calibration dates of meters SM1, SM2, SM3 & SM4 are more than 5 years old.

**Hamirpur Town**

Calibration dates of meters from SM1 to SM8 are more than 5 yrs old.

*Contd. 8/2*

**Nahan Town**


In Executive Summary Units of Energy & Amount seems to be incorrect.

**Chamba Town**

Calibration dates of meters from SM1 to SM9 are more than 5 yrs old.

You are therefore requested to kindly submit final reports of above 5 towns after incorporating the above comments and the same may also be taken care off while submitting the reports of balance towns.

Thanking you,



25/11/2011

Ali Shah

Nodal Officer (RAPDRP-HP)

**Copy to:**

1. Chief Engineer (SO)  
Himachal Pradesh State Electricity Board Ltd,  
Vidyut Bhavan, Shimla -141004.
2. Superintending Engineer (IT)  
Himachal Pradesh State Electricity Board Ltd,  
Vidyut Bhavan, Shimla -141004.
3. Dy. Superintending Engineer (IT)  
Himachal Pradesh State Electricity Board Ltd,  
Vidyut Bhavan, Shimla -141004.