

Clarifications to Bid Documents for ring fencing meters due on 15th December 2009.

Sr. No	Clause No.	Description	Bidder's queries	HPSEB's clarifications
Section-VIII, GTP				
1.	30	No. of ToD registers	ToD features are not applicable for boundary meters	ToD feature is not applicable in case of ring fencing meters
2.	39 a)	Load survey capability a) 30 min demand for atleast last 60 days	As per Table 3.2 of Companion standard dated: 14/10/2009, load survey of 5 parameters for last 22 days is to be provided in the meter	Provision existing in Companion standard dated: 14/10/2009 shall prevail.
3.			History of billing data is not required in the boundary meter	History of billing data is not required
4.	Note: In case of any discrepancy in the technical specifications stated in the Bid Documents, the provisions contained in Companion standard dated: 14/10/2009 shall prevail.			